



Match Line

1 FLOOR PLAN 'B' - LIGHTING
1/8" = 1'-0"

2 NOTES

1. ALL LIGHTING FIXTURES NOT INDICATED OTHERWISE SHALL BE TYPE 'RB'.
2. PROVIDE THREE SWITCHES DESIGNATED 'A', 'B', & 'C' TO CONTROL CAFE LIGHTING. SWITCH 'A' SWITCH SHALL BE CLOSEST TO DOOR. 'B' FOR OTHER SWITCHES. 'C' SWITCH SHALL BE CLOSEST TO DOOR.
3. PROVIDE UNISTRUT BETWEEN JOISTS FOR MOUNTING OF TYPE 'SP' FIXTURES.
4. PROVIDE FOUR SWITCHES DESIGNATED 'S1', 'T1', 'U', & 'V' TO CONTROL GYM LIGHTING FIXTURES. ALL SWITCHES SHALL BE 5-WAY. 'S' SWITCHING STAIR CENTER 'P' FOR OTHER SWITCHES. 'S' SWITCH SHALL BE CLOSEST TO STAIR CENTER.
5. See DETAIL 02-3 FOR SWITCHING CENTER 'P' LAYOUT.
6. CONNECT FIXTURES THROUGH TRANSFER RELAY - See DETAIL 10E-3.
7. CONNECT TWO (2) LAMPS IN EACH FIXTURE THROUGH TRANSFER RELAY - See DETAIL 10E-3.
8. PROVIDE WALL-MOUNTED, FLUORESCENT (TYPE 'WA') ON WALL ABOVE ENTRANCE TO STAIRS TO PLATFORM.

3 LIGHTING FIXTURE LEGEND

	TYPE 'RA'		TYPE 'SA'
	TYPE 'PAB'		TYPE 'B4'
	TYPE 'RB'		TYPE 'XC1'
	TYPE 'RBE'		TYPE 'XC2'
	TYPE 'RD'		TYPE 'XW1'
	TYPE 'RE'		TYPE 'XW2'
	TYPE 'REE'		TYPE 'WE'
	TYPE 'PA'		

